### Gas Phase Sensor Development at LLNL



### Bob Glass, Quoc Pham, Peter Martin, Brandon Chung

Energy & Environment Directorate Lawrence Livermore National Laboratory

Annual SECA Core Technology Review Pittsburgh, PA

June 18-19, 2002

# A variety of sensor technologies can be considered for gas phase sensing



• Electrochemical

• Optical


• Thermal

• Mass

Glass SEC

# Solid state electrochemical sensors have a proven history in high temperature, chemically harsh environments - the EGO sensor is simple and rugged





(From E.M. Logothetis in Chemical Sensor Technology, 3, Kodansha Ltd.: 1991, p. 89)

Glass SECA

# Automotive industry and fuel cell criteria for sensors are similar



- Reliability
- Sensitivity
- Selectivity
- Durability
- Manufacturability
- Integration
- Low cost

Need materials which can provide adequate response while surviving prolonged operation in a high temperature, high stress, corrosive environment

Class SI

# Additional exhaust emission sensor requirements





Exposure to a variety of	Nitrogen	77.4%	Nitrogen oxides	0.1%				
gases, with approximate	Hydrogen	0.3%	Oxygen	1%				
composition out of the engine:	Carbon dioxide	10%	Sulfur dioxide	0.1%				
	Hydrocarbons	0.1%	Carbon monoxide	1%				
	Water	10%	P, Si, Zn, Mn	Trace				
Temperature:	-40 to 800°C, with spikes to 950°C possible							
Flow rates:	10-30 g/s normal; maximum of 150 g/s							
Pressure:	30 inches of mercury							
Shock:	Mechanical shock of 50 G with vibration levels to 15 G							
Ele c tronic:	Radio frequency compatibility to meet corporate/government standards. No EMI interference							
Life time:	10 years or 100,000 miles without intervention							
Calibration:	Self-calibrationg; short- and long-term drifts not permitted							
Response time:	1 second or less preferred. Need not monitor individual cylinder events							
Size:	Packaging must fit under vehicle body							
Power:	Compatible with 12 V DC							
Other:	Must be totally interchangeable (10 million devices/year)							
Me as ure ment s trategy:	If relations hip is inferred (e.g. measure hydrogen and infer HC), it must be robust, well-established, and documented							

# There are two operational modes for electrochemical sensors



#### Potentiometric Oxygen Sensors






Stoichiometric Air/Fuel Ratio


(a) Potentiometric (O<sub>2</sub> sensor example)

$$E = \frac{RT}{nF} \ln \left( \frac{P_1}{P_2} \right)$$

– Insensitive over much of oxygen range

#### Amperometric Oxygen Sensors





Stoichiometric Air/Fuel Ratio

(b) Amperometric (O<sub>2</sub> sensor example)

$$i_{i} \propto C$$

- Linear over much of oxygen range

less CECA

# **Electrochemical sensors for PEMFC vehicles - technical targets**



### • Hydrogen "safety" sensor

- 0.1 to 10% hydrogen in ambient air
- Response time under 1 second

### • Hydrogen sensor

- 1 to 100% hydrogen concentration in fuel gas
- Response time of 0.1 to 1 second for 90% response

#### CO sensor


- 1 to 1000 ppm CO in fuel gas
- Response time of 0.1 to 1 second

### Approach




- Use proven technology: zirconia-based oxygen sensor
- Develop mixed potential electrodes that are sensitive to hydrogen for use without the need of a reference gas

Mixed potential electrode that is sensitive to hydrogen



### Experimental set up







# With nanocrystalline electrode, sensor response time is reduced to 2-3 s



We use the Colloidal Spray Deposition technique to deposit the nanocrystalline metal oxide electrode.






Sensor response to hydrogen in air at 500°C.

The response time is 2-3 s. However, the recovery time is much longer


Time between 2 data points: 1 s

# Sensor has good selectivity






 Sensor is one order of magnitude more sensitive to hydrogen than to methane



- Sensor response level identical when switch from dry to humid atmosphere (100% RH)
- Response time is <3 sec
- Recovery time is < 200 sec

# No drifting has been observed






- Baseline drifting is a major issue with conventional resistive sensors
- No baseline drifting nor signal amplitude change were observed with the mixed potential sensor

# Hydrocarbon sensor development for on-board monitoring of catalytic converter performance






**ULEV Standards** 

### Principle of LLNL hydrocarbon sensor



#### Hydrogen Sensor

Proton Conducting Electrolyte



 $E = RT/nF ln (P_1/P_2)$ 

#### LLNL Hydrocarbon Sensor

Exhaust Gas


dehydrogenation catalyst

Possible Catalytic Reactions:

- dehydrogenation
- steam reforming
- cracking

# First generation HC sensor






t (s)

SZY: SrZr<sub>0.9</sub>Y<sub>0.1</sub>O<sub>3</sub>

# The problem was a strong effect of oxygen on sensor signal






The effect of oxygen may come from the reaction between hydrogen and oxygen

### Second generation sensor design



Old design: two Pt electrodes with the HC decomposition catalyst covering one electrode New design: the catalyst is also one of the 2 electrodes




Problem: Pt catalyses the hydrogen oxidation, causing strong influence of the oxygen concentration on sensor signal

The correct selection of the catalyst can minimize the hydrogen oxidation, thus reducing the oxygen effect

# Effect of oxygen concentration on sensor response







The new sensor is significantly less sensitive to oxygen concentration in exhaust gas

### Sensor response to hydrocarbons



#### Response to n-butane






Flow = 1L/min  

$$[O_2] = 0.1\%$$
  
 $[C4H10]_{stoich.} = 154 ppm$ 

The sensor can be used in both lean-burn and fuel rich conditions

# Sensor response in the presence of CO and HC






Unlike the older generation sensors, the new sensor is virtually insensitive to the presence of CO, even when both CO and HC are present in the exhaust gas

Glass SECA

# Results of the Dynamometer testing of LLNL NMHC sensor at Ford Laboratories





Exhaust Hydrocarbon Concentration (FID ppm C<sub>3</sub>)

# Approaches to increase the electronic conduction in the catalyst layer




• Indium doped zinc oxide

• Bi-layer ZnO/Au







Au


ZnO

Glass - S


# **Composite ZnO + ITO catalyst**








# Sensor response to C4H10 at 750°C



- Catalyst composition is 60/40 mole % of ZnO/ITO. There is a continuous conduction path in the catalyst
- Response time is about 2 s. This is the limit of the gas phase exchange in the test chamber!

### **Sensor sensitivity**





- The sensitivity to propylene is unusually high
- **Detection limit could be below 1 ppm propylene**
- The detection mechanism is unclear
- R.t at 650°C is 4 to 8 s

# Improved NO<sub>x</sub> sensing technology is needed for new vehicle emissions monitoring requirements




- Most advanced current design (electrochemical) is complex, expensive to fabricate, and suffers from poor stability and selectivity
- We are developing a solid state electrochemical  $NO_x$  sensor for compression ignition direct injection (CIDI) engines that has high selectivity and low fabrication cost
- Target performance:
  - Sensitivity to  $NO_x$ : 1 1,000 ppm at operating T > 400° C
  - Response time: 1 second or less
  - Minimized (or no) cross-sensitivity to O<sub>2</sub>, SO<sub>x</sub>, NH<sub>3</sub>, urea, HCs, etc.
  - Long term stability
  - Packagable/Integratable

Glass SEG

# NiCr<sub>2</sub>O<sub>4</sub> sensor with a current bias gives increased NO sensitivity and 90% recovery time of ~1.5 seconds





 $NO_2$  sensitivity is high: > +90 mV (500 ppm) with 90% recovery in ~4 seconds

Clara SEC





Engine exhaust (vol. %)					
Nitrogen	77.4				
Nitrogen oxides	0.1				
Hydrogen	0.3				
Oxygen	1				
Carbon dioxide	10				
Sulfur dioxide	0.1				
Hydrocarbons	0.1				
Carbon Monoxide	1				
Water	10				
P, Si, Zn, Mn	Trace				


Reformed gasoline composition (vol. %)					
Component	Before SOX (PROX)	After SOX (PROX)			
$H_2$	34.8	32.1			
H <sub>2</sub> O	28.6	29.1			
$\mathrm{CH_4}$	0.4	0.4			
CO	0.7	<10 ppm			
$CO_2$	14.8	14.9			
$N_2$	20.4	23.2			
Ag	0.3	0.3			

Gas composition from a pressurized, fluidized-bed coal gasifier (vol. %)									
	$H_2$	CO	$CH_4$	$H_2O$	$CO_2$	$N_2$	$H_2S$	COS	$NH_3$
Air mode	16.8	27.9	1.8	3.8	2.8	46.0	0.68	0.02	0.16
Oxygen mode	29.4	38.0	4.0	17.3	9.5	0.54	1.07	0.02	0.24

Clara SEC

# Sensors for diagnostics and feedback control for fuel cell systems





June 2002



# **Summary**



- Solid state electrochemical sensors can meet the demands of operation in harsh environments
- Fuel cell performance can be optimized with embedded sensors
- Chemical sensors take a long time to develop don't wait!
- Nothing is perfect

Glass SEC